





**2013
CA. RESIDENTIAL CODE
R11.7.8**


“Handrail ends shall return to the wall or guardrail post or shall have rounded terminations or bends.”



HANDRAIL AND STAIR DETAIL



ACCEPTABLE SHAPES AND INSTALLATIONS—HANDRAIL



THE HANDRAIL DETAIL SHOWN HERE DOES NOT COMPLY WITH THE
“CONTINUOUS” TERMINOLOGY IN THE CODE.

HANDRAIL CONTINUITY